



KORPORATA FITOSANITARE  
 "SARA & METI" Sh.p.k.  
 Rr. Kamer Loshi Nr. 24, Prishtinë,  
 Tel: 044/213-795, 044/ 406-717

**Testing Report**

**Nr.114/21**

**Analytical, Agriculture and Food Laboratory**

- |                         |   |
|-------------------------|---|
| 1. Date of sampling     | 09.02.2021  |
| 2. Sample to be tested  | Wastewater sample   |
| 3. Requested analysis   | Physico-chemical analysis   |
| 4. Sample submitted by  | Tomor Gashi   |
| 5. Company              | N.N.T. PROTECH. Nr.Unik: 810454116. Prishtinë   |
| 6. Title of the Project | Design and Build: Waste Water Treatment Plant. Camp Film City. Kosova.<br>Investor: NATO Support and Procurement Agency |
| 7. Manner of sample     | The sample has been submitted to the laboratory by applicant  |

**Table 1. Results of testing**

Parameter	Measuring unit	Results	Referent Values Administrative Instruction MESP No.30/2014	A[plied method
1 Total Suspended Solids –Non filterable residue (TSS)	mg/L	54	< 60	EPA method 160.2
2 Chemical Oxygen Demand (COD)	mg/L	107	< 125	EPA method 410.1
3 Biochemical Oxygen Demand (BOD <sub>5</sub> )	mg/L	19	< 25	EPA method 405.1
4 Total Nitrogen	mg/L	5.1	< 10	EPA method 351.3
5 Total Phosphorus	mg/L	1.3	< 2.0	EPA method 365.2
6 Oil and greases	mg/L	6.5	< 30	EPA method 413.1

Prishtina

Date: 16.02.2021



dpt. Quality Manager

Dr. sc. Fadil Musa

**Notes:** Results are valid only for this sample. This report is prohibited to be copied